

BORDEN PARISH HALL REPORT APRIL 2024

1. The fire alarm test was carried out on 8-4-24 and no problems found.
2. The faulty hall heaters were looked at by Vulcana and one was repaired. The second heater has a failed press button switch which an electrician is replacing.
3. The Hall insurance is being reviewed prior to the forthcoming renewal date.
4. Non discretionary rates for Halls may be revised and the impact on the Hall finances will need to be assessed.

John Hepburn

Chairman Borden Parish Hall